

CERTIFICATE OF COMPLIANCE

Certificate Number 20140218-EX15624
Report Reference EX15624-20131227
Issue Date 2014-FEBRUARY-18

Issued to: ROTAREX INC NORTH AMERICA
WESTMORELAND TECHNOLOGY PARK 1
221 WESTEC DR
MT PLEASANT PA 15666


This is to certify that representative samples of CLEAN AGENT EXTINGUISHING SYSTEM UNITS
“See Addendum Page”

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 2166 - STANDARD FOR HALOCARBON CLEAN AGENT EXTINGUISHING SYSTEM UNITS

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word “LISTED”; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140218-EX15624
Report Reference EX15624-20131227
Issue Date 2014-FEBRUARY-18


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Pre-Engineered Models FireDETEC ILP Clean Agent Extinguishing System Units containing HFC-227ea, stored pressure type, having nominal storage capacities of 3, 7 and 14 lbs. The units are super-pressurized with dry nitrogen to 240 psi at 70°F (21°C) with operating temperatures of +32°F to +130°F (0°C to 54°C). The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These systems are intended to be designed and installed in accordance with the Listee's Installation and Design manual, Part No. 027650004, issued December 2013.

SYSTEM UNIT ASSEMBLIES

Nominal Capacity, lb	Part Number	Valve Size, in.	Fill Weight, lb	Fill Weight, kg	Charging Pressure, psi (bar)
3	B07014500	¼	3	1.36	240
7	B07014501	½	7	3.18	240
14	B07014502	½	14	6.35	240



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

