

## Certificate of Product Approval

Certificate Number: 724b

Issue: 03

### Ceodeux Extinguisher Valves Technology S.A. (FIRETEC)

24 rue de Diekirch - B.P.19  
L-7505 Lintgen  
Luxembourg



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Products

##### Fixed Fire Extinguishing Systems For Catering Equipment

Rotarex FireDETEC, wet chemical, restaurant fire suppression system.

#### Standards

##### LPS 1223: Issue 2.3

Requirements and Testing Procedures for the LPCB Certification and Listing of Fixed Fire Extinguishing Systems for Catering Equipment.

This certificate and appendix is maintained and held in force through regular surveillance activities

*S. A. Colwell*

Signed for LPCB

Sarah Colwell  
Verifier

10 October 2014  
Date of Issue

28 July 2014  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

## Appendix to Certificate No: 724b Ceodeux Extinguisher Valves Technology S.A. (FIRETEC)

Issue: 03

### Rotarex FireDETEC to LPS 1223: issue 2.3

Product Name	Designation	Description	LPCB Ref. No.
Rotarex FireDETEC, wet chemical, restaurant fire suppression system.	B07503000	9 litre, Manual and Automatic operation, wet chemical extinguishant	724b/01
Rotarex FireDETEC, wet chemical, restaurant fire suppression system.	B07503001	9 litre, Manual and Automatic operation, wet chemical extinguishant	724b/02

#### Note:

Rotarex FireDETEC, wet chemical restaurant fire suppression systems shall be installed, maintained and operated in accordance with Rotarex FireDETEC, Installation and Maintenance Manual FireDETEC System kits for kitchen version 07/2013.

This certificate and appendix is maintained and held in force through regular surveillance activities

*S. ACdwell*

Signed for LPCB

Sarah Colwell  
Verifier

10 October 2014  
Date of Issue

28 July 2014  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [Enquiries@breglobal.com](mailto:Enquiries@breglobal.com)



**bre**